

## Detailed Latest Test Results



Test Status: All, Test Type: All  
 Person: All, Instrument: All  
 From: 4/1/2018 To: 5/2/2018

Site: Q THE MUSIC		Location: MAIN OFFICE		
Asset ID: 5195	Description: EQUINOX WARP	User: STEVEN	Test Instrument: 26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
Overall: Pass				
Asset ID: 5196	Description: EQUINOX WARP	User: STEVEN	Test Instrument: 26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
Overall: Pass				
Asset ID: 5197	Description: IEC	User: STEVEN	Test Instrument: 26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
IEC Lead Continuity	4/28/2018	0.078	ohm	Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
IEC Lead Polarity	4/28/2018			Pass
Overall: Pass				
Asset ID: 5198	Description: IEC	User: STEVEN	Test Instrument: 26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
IEC Lead Continuity	4/28/2018	0.104	ohm	Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
IEC Lead Polarity	4/28/2018			Pass
Overall: Pass				
Asset ID: 5199	Description: IEC	User: STEVEN	Test Instrument: 26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
IEC Lead Continuity	4/28/2018	0.158	ohm	Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
IEC Lead Polarity	4/28/2018			Pass
Overall: Pass				
Asset ID: 5200	Description: IEC	User: STEVEN	Test Instrument: 26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
IEC Lead Continuity	4/28/2018	0.128	ohm	Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
IEC Lead Polarity	4/28/2018			Pass
Overall: Pass				
Asset ID: 5201	Description: IEC	User: STEVEN	Test Instrument: 26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
IEC Lead Continuity	4/28/2018	0.048	ohm	Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
IEC Lead Polarity	4/28/2018			Pass
Overall: Pass				
Asset ID: 5202	Description: IEC	User: STEVEN	Test Instrument: 26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
IEC Lead Continuity	4/28/2018	0.14	ohm	Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
IEC Lead Polarity	4/28/2018			Pass
Overall: Pass				

# Detailed Latest Test Results



Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 4/1/2018 To: 5/2/2018

Asset ID: 5203	Description: IEC	User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit Status
Visual	4/28/2018		Pass
IEC Lead Continuity	4/28/2018	0.054	ohm Pass
Insulation Voltage	4/28/2018	500	V Information
Insulation	4/28/2018	> 199	MOhm Pass
IEC Lead Polarity	4/28/2018		Pass

Overall: Pass

Asset ID: 5204	Description: IEC	User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit Status
Visual	4/28/2018		Pass
IEC Lead Continuity	4/28/2018	0.056	ohm Pass
Insulation Voltage	4/28/2018	500	V Information
Insulation	4/28/2018	> 199	MOhm Pass
IEC Lead Polarity	4/28/2018		Pass

Overall: Pass

Asset ID: 5205	Description: IEC	User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit Status
Visual	4/28/2018		Pass
IEC Lead Continuity	4/28/2018	0.06	ohm Pass
Insulation Voltage	4/28/2018	500	V Information
Insulation	4/28/2018	> 199	MOhm Pass
IEC Lead Polarity	4/28/2018		Pass

Overall: Pass

Asset ID: 5206	Description: IEC	User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit Status
Visual	4/28/2018		Pass
IEC Lead Continuity	4/28/2018	0.066	ohm Pass
Insulation Voltage	4/28/2018	500	V Information
Insulation	4/28/2018	> 199	MOhm Pass
IEC Lead Polarity	4/28/2018		Pass

Overall: Pass

Asset ID: 5207	Description: IEC	User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit Status
Visual	4/28/2018		Pass
IEC Lead Continuity	4/28/2018	0.044	ohm Pass
Insulation Voltage	4/28/2018	500	V Information
Insulation	4/28/2018	> 199	MOhm Pass
IEC Lead Polarity	4/28/2018		Pass

Overall: Pass

Asset ID: 5208	Description: IEC	User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit Status
Visual	4/28/2018		Pass
IEC Lead Continuity	4/28/2018	0.034	ohm Pass
Insulation Voltage	4/28/2018	500	V Information
Insulation	4/28/2018	> 199	MOhm Pass
IEC Lead Polarity	4/28/2018		Pass

Overall: Pass

Asset ID: 5209	Description: IEC	User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit Status
Visual	4/28/2018		Pass
IEC Lead Continuity	4/28/2018	0.066	ohm Pass
Insulation Voltage	4/28/2018	500	V Information
Insulation	4/28/2018	> 199	MOhm Pass
IEC Lead Polarity	4/28/2018		Pass

Overall: Pass

Asset ID: 5210	Description: IEC	User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit Status
Visual	4/28/2018		Pass
IEC Lead Continuity	4/28/2018	0.156	ohm Pass
Insulation Voltage	4/28/2018	500	V Information
Insulation	4/28/2018	156	MOhm Pass
IEC Lead Polarity	4/28/2018		Pass

Overall: Pass

# Detailed Latest Test Results



Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 4/1/2018 To: 5/2/2018

Asset ID:	Description:	User:	Test Instrument:	
5211	IEC EXTENSION	STEVEN	26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
IEC Lead Continuity	4/28/2018	0.148	ohm	Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	186	MOhm	Pass
IEC Lead Polarity	4/28/2018			Pass
Overall: Pass				
5212	IEC EXTENSION	STEVEN	26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
IEC Lead Continuity	4/28/2018	0.214	ohm	Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
IEC Lead Polarity	4/28/2018			Pass
Overall: Pass				
5213	SURGE LEAD	STEVEN	26D-0216	
Test Type	Date	Result	Unit	Status
IEC Lead Continuity	4/28/2018	0.146	ohm	Pass
Visual	4/28/2018			Pass
IEC Lead Polarity	4/28/2018			Pass
Overall: Pass				
5214	EXTENSION LEAD	STEVEN	26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
IEC Lead Continuity	4/28/2018	0.136	ohm	Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
IEC Lead Polarity	4/28/2018			Pass
Overall: Pass				
5215	EXTENSION LEAD	STEVEN	26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
IEC Lead Continuity	4/28/2018	0.14	ohm	Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	189	MOhm	Pass
IEC Lead Polarity	4/28/2018			Pass
Overall: Pass				
5216	CAM LAZER	STEVEN	26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	153	MOhm	Pass
Overall: Pass				
5217	VF400	STEVEN	26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
Overall: Pass				
5218	LX5	STEVEN	26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
Overall: Pass				
5219	LX5	STEVEN	26D-0216	
Test Type	Date	Result	Unit	Status
Visual	4/28/2018			Pass
Insulation Voltage	4/28/2018	500	V	Information
Insulation	4/28/2018	> 199	MOhm	Pass
Overall: Pass				

# Detailed Latest Test Results



Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 4/1/2018 To: 5/2/2018

Asset ID: 5220		Description: MR COOL		User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit	Status	
Visual	4/28/2018			Pass	
Insulation Voltage	4/28/2018	500	V	Information	
Insulation	4/28/2018	> 199	MOhm	Pass	
Overall: Pass					

Asset ID: 5221		Description: AC ADAPTER		User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit	Status	
Visual	4/28/2018			Pass	
Insulation Voltage	4/28/2018	500	V	Information	
Insulation	4/28/2018	> 199	MOhm	Pass	
Overall: Pass					

Asset ID: 5222		Description: ZIPPER		User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit	Status	
Visual	4/28/2018			Pass	
Insulation Voltage	4/28/2018	500	V	Information	
Insulation	4/28/2018	> 199	MOhm	Pass	
Overall: Pass					

Asset ID: 5223		Description: SPEAKER		User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit	Status	
Visual	4/28/2018			Pass	
Insulation Voltage	4/28/2018	500	V	Information	
Insulation	4/28/2018	> 199	MOhm	Pass	
Overall: Pass					

Asset ID: 5224		Description: SPEAKER		User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit	Status	
Visual	4/28/2018			Pass	
Insulation Voltage	4/28/2018	500	V	Information	
Insulation	4/28/2018	> 199	MOhm	Pass	
Overall: Pass					

Asset ID: 5225		Description: SUBWOOFER		User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit	Status	
Visual	4/28/2018			Pass	
Insulation Voltage	4/28/2018	500	V	Information	
Insulation	4/28/2018	> 199	MOhm	Pass	
Overall: Pass					

Asset ID: 5226		Description: AC ADAPTER		User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit	Status	
Visual	4/28/2018			Pass	
Insulation Voltage	4/28/2018	500	V	Information	
Insulation	4/28/2018	> 199	MOhm	Pass	
Overall: Pass					

Asset ID: 5227		Description: DMX		User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit	Status	
Visual	4/28/2018			Pass	
Insulation Voltage	4/28/2018	500	V	Information	
Insulation	4/28/2018	> 199	MOhm	Pass	
Overall: Pass					

Asset ID: 5228		Description: BUBBLE MACH		User: STEVEN	Test Instrument: 26D-0216
Test Type	Date	Result	Unit	Status	
Visual	4/28/2018			Pass	
Insulation Voltage	4/28/2018	500	V	Information	
Insulation	4/28/2018	1.05	MOhm	Pass	
Overall: Pass					

Total Tests: 34